



*First Results
Approved*

*SP
To Release drawings with
Amended instructions on mesh*

FACSIMILE

التاريخ: 6.12.06

إشارتنا:

TO : GULF GLASS FIBRE W.L.L
ATTENTION : Mr. SHIVA BHARDWAJ - GENERAL MANAGER
FAX NUMBER : 4602659
COUNTRY : State of Qatar

FROM : ACTING MANAGER, O&M DEPT. - DRAINAGE AFFAIRS
NO. OF PAGES : 01 (including this page)

If this Fax message is incomplete / unclear please call on 4950055 quoting the above Fax Ref. No.

SUBJECT: SHOP DRAWING

REF : FABRICATION OF DEODORIZER VESSEL @ PS14/1, W.O # 2006/123

We refer to your fax GGF/06/116 dated 23rd November 2006 regarding the above subject, and hereby clarify that the said shop drawing (ASG/GGF/DNB-900/01) is **approved** with the following comments.

1. 'Stainless Steel Mesh' should be provided instead of PP Mesh.
2. Dimensions and design shown are accepted and to be followed during fabrication.

This is for your information, records and further proceedings at the earliest.

Regards,

AHMED M. SHERIEF
ACTING MANAGER OF O&M DEPT.

c.c.: Operation & Maintenance Department
Hamad G. Al Marri - Head of Networks Division
Abdul Hameed Al Batal - Area Engineer
Ali Saad Salem - Mechanical Engineer
File

*Released drawing
to Production with
above changes on.
7/12/06.*

*SP
7/12/06.*

HM / AHB

HM / AHB / SA-06/12/06